



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY SERVICES
AGARTALA : TRIPURA

Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

Application Reference No: FSRTFES/2022/00212

Dated: 11/11/2022

ACKNOWLEDGEMENT CUM MONEY RECEIPT

Applicant's Details			
Name	Merciful Nongsiej		
Mobile	8974859438	E-Mail	auxi_agartala@yahoo.com
Building Address	Area Name Nandan Nagar, Ward No.6, Agartala Municipal Corporation, Post Office Nandannagar B.O - 799006, West Tripura District, Tripura.	Police Station	New Capital Complex

Payment Details:

GRN 22315AE591
CIN 107052811
Txn Date 11/11/2022
Amount 3000.00
Status Success

Fees paid is non refundable

For
Directorate of Fire & Emergency Services

Annexures Details

Type of document(s)	Document(s) Attached
Existing Building Plans	Existing Building Plans
Drawings of the proposed fire protection arrangements	Drawings of the proposed fire protection arrangements



Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451 Fax: 0381-2324826 Email: dfireservicetripura@gmail.com Website: www.fireservice.tripura.gov.in

No. 3-8/TFES/2021/ 10491-93

Dated, Agartala, the 02nd ^{Dec} November, 2021

To
The Principal,
Auxilium Girls' School,
Nandannagar, Agartala, West Tripura.
Ph. No. 9402168586.

Subject: - Issuance of renewal Fire NOC.

Sir,

With reference to the letter No. Auxil/Agt/FS/2021-22/01 dated 02.10.2021, it is hereby certified that the building/premises as per description below has been inspected by the officer concerned of this department on 17.11.2021. In respect of implementation of Fire Safety measures, it was found that said building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016. Therefore, the premises/building is issued Temporary NOC with effect from 01/12/2021 for a period of 01 (one) month subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building/premises. :- "Auxilium Girls' School", Nandannagar, Agartala, West Tripura

Issued on 01/12/2021 at Agartala.

N.B. Department has switched over offline issuance of NOC to online. Therefore provisional / Temporary NOC is issued for a period of 01 (one) month. Thereafter, application to be submitted online (edistrict.tripura.gov.in) for Final Fire NOC.

Yours faithfully,

Joint Director,
Tripura Fire & Emergency Services

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:-

1. The Divisional Fire Officer, West Division, Agartala, Tripura for favour of information.
2. The Fire Prevention Officer, OC, Agartala F&ES Station for information.