

## State Level Water Testing Laboratory

**PWD(DWS), Government of Tripura**  
**P.N. Complex,**  
**Agartala - 799006**  
**Tel : 0381-2327362, Fax : 0381-2327362**  
**Website : [www.dwstripura.in](http://www.dwstripura.in)**



### TEST REPORT

Name & Address of the customer

Principal, Auxilium Girls School,  
 Agartala, Water sample from  
 Auxilium Girls School,  
 Agartala, Tripura


Report No : SLWTL/2017/3656  
 Report Date : 05/03/2019  
 Sample ID : 980GXP7C6L  
 Date of Receipt of Sample : 02/03/2019, 01.45 pm  
 Date(s) of Performance : 05/03/2019  
 Ref. No. & Date : NIL

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results :


1.	Description of Sample (As declared by customer)	: Drinking Water

2.	Sample Mark (if any, given by the customer)	: NA
3.	Date of Sampling by the Customer	: 02/03/2019
4.	Source & Place of Sampling	: Water sample from Auxilium Girls School, Agartala.
5.	Environmental conditions during sampling	: NA
6.	Sampling Plan & Procedures used	: NA

**Report****Prepared by**

Signature :   
 Name : Anil Nandi  
 Designation : Lab Assistant

**For State Level Water Testing Laboratory**

Signature :   
 Name : Debasish Bhattacharya  
 Designation : Scientific Officer  
**Authorized Signatory**

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of State Level Water Testing Laboratory
- The reserved part of sample(s) shall be retained for 30days from the date of Completion of Test.

Contact Person : Er. Rajib Maumder,

Quality Manager, State Level Water Testing Laboratory

Tel : 0381-2327362, Fax : 0381-2327362, Email : [gmstipura@gmail.com](mailto:gmstipura@gmail.com), Website : [www.dwsstripura.in](http://www.dwsstripura.in)

# State Level Water Testing Laboratory

PWD(DWS), Government of Tripura  
 P.N. Complex,  
 Agartala - 799006  
 Tel : 0381-2327362, Fax : 0381-2327362  
 Website : [www.dwstrippura.in](http://www.dwstrippura.in)



Report No : SLWTL/2017/3656  
 Sample ID : 980GXP7C6L

## Analysis of Result

SN	Characteristic	Acceptable Limit	Permissible Limit	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 23rd Edition 2130 B	0.14
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 23rd Edition 4500-H+ B.6.12	
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 23rd Edition 3500-Fe B	0.045

BDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l,  
 Magnesium - <2 mg/l, Manganese - <0.01 mg/l49">

## Report Prepared by

Signature

Name : **Anil Nandi**

Designation : **Lab Assistant**

## For State Level Water Testing Laboratory

Signature

Name : **Debashish  
Bhattacharya**

Designation : **Scientific  
Officer**

**Authorized Signatory**

Contact Person : **Er. Rajib Majumder**

Quality Manager, State Level Water Testing Laboratory,

Tel : 0381-2327362, Fax : 0381-2327362, Email : [qmg@dwstrippura@gmail.com](mailto:qmg@dwstrippura@gmail.com), Website :

[www.dwstrippura.in](http://www.dwstrippura.in)